

**Intertek**

## Performance Test Certificate

Issued To

MIDDLE EAST METAL & WOOD INDUSTRIES  
CO. LTD. (METALCO)

Intertek tested a representative sample of a  
Middle East Metal & Wood Industries  
SN-70-M3-RHR-SAMPLE-(XXX) DOOR

A 35 1/8 inch wide by 84 1/4 inch high by 2 3/4 inch thick door  
was tested in a 12 gauge metal frame with  
Zero 566A, 475AA and 118B spring bronze on the head and jamb and a 367AA  
automatic door bottom and then with the 118B removed.

### STANDARDS

ASTM E90-2009 "Standard Test Method for Laboratory Measurement  
of Airborne Sound Transmission Loss of Building Partitions"


ASTM E413-2004 "Classification for Rating Sound Insulation"

### RESULTS OF TEST

The system was tested and rated in accordance with the referenced  
standards and was determined to have a  
Sound Transmission Class Rating (STC) of **46 and 42**.

"Reference Intertek Report Number 100018736CRT-001b, dated April 21, 2010"

Date: September 27, 2010



James R. Kline  
Intertek  
Engineer / Quality Supervisor

This Verification is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Verification. Only the Client is authorized to copy or distribute this Verification. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results referenced from this Verification are relevant only to the sample tested. This Verification by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.