

The Intertek logo is a blue rounded rectangle with the word "Intertek" in white, bold, sans-serif font.

## CERTIFICATE OF COMPLIANCE

**THIS CERTIFIES** that **MIDDLE EAST METAL & WOOD INDUSTRIES CO. LTD. (METALCO)** formerly known as **METALCO** is listed by Intertek/Warnock Hersey as a manufacturer of Vertically Stiffened Fire-Rated Stainless Steel Doors and is authorized to produce and supply labeled fire doors with the following ratings in accordance with the standards of: UL 10C (2001), UL 10B (1997), "Standard for Safety Fire Tests of Doors Assemblies", UBC 7-2-1994 (Part 1), UBC 7-2-1997, "Fire Tests of Door Assemblies", NFPA 252-1999 "Standard Methods of Fire Tests of Door Assemblies", and BS 476 Part 22.

Configuration

Nominal Size

Duration

Standard Pair without Astragal

8' wide x 9' high (2438 x 2743)

90 minutes

Standard Pair with Astragal

8' wide x 9' high (2438 x 2743)

180 Minutes

Double Egress

Not Allowed


N.A.

**THIS CERTIFICATE** is only valid under Intertek/WHI Testing, Inspection and Labeling Services. Intertek/Warnock Hersey Certified products **MUST** bear a certification label showing the WHI logo and the hourly rating of the product.

Issued: June 1, 2009

Expires: December 31, 2010

By:

  
Bob Davison  
Certification Manager

**Intertek Testing Services NA, Ltd.**

6225 Kenway Drive, Mississauga, Ontario, Canada L5T 2L3

Telephone: (905) 678-7820 Fax: (905) 362-0303

Web: [www.intertek-erisenko.com](http://www.intertek-erisenko.com) Email: [bob.Davison@intertek.com](mailto:bob.Davison@intertek.com)