

CERTIFICATE OF APPROVAL
No. ME0114

This is to certify that the referenced products of

Middle East Metal and Wood Industries Co Ltd.

P.O Box 502, Riyadh 11383, Kingdom of Saudi Arabia
Tel: +966 1 265 0 666 Fax: +966 1 265 0 688

have been assessed against the requirements of the *warringtonfire – mideast certification scheme* and are approved for use within the scope of the test and/or assessment report(s) referenced.

Mineral Composite Based FD90 Doorsets

**90 Minutes Integrity and Insulation Performances In Accordance
With BS 476: Part 22: 1987**

Assessment Report Reference	Valid Until
Report WF No. 173490	1st February 2014

Approved Maximum Door Leaf Dimensions			
Configuration	Leaf Height (mm)	Leaf Width (mm)	Leaf Area (m²)
Latched, Single-Acting, Single-Leaf, 62 mm thick	2650 (At 1045 wide)	1306 (At 2119 high)	2.77
Latched, Single-Acting, Double-Leaf, 62 mm thick (note: inactive leaf flush bolted top & bottom, active leaf latched to inactive leaf at mid-height)	2650 (At 1045 wide)	1306 (At 2119 high)	2.77

Page 1 of 3

Certification is awarded on the basis of initial type testing and assessment to BS 476: Part 22: 1987, initial inspection and ongoing surveillance of factory production control, and ongoing compliance with the scheme requirements including the use of labels supplied by Bodycote **warringtonfire**. The currency of the certification may be verified at www.warringtonfire.net/mideast

Signed for and on behalf of Warrington Certification



Sir Ken Knight
Chairman - Management Council

Issued: 6th February 2009
Valid to: 5th February 2014